

Appendix J-8
SONIR Model Results: Alternative 5

SIMULATION OF NITROGEN IN RECHARGE (SONIR)

NELSON, POPE & VOORHIS, LLC MICROCOMPUTER MODEL

NAME OF PROJECT

**Indian Hills - Alternative 5
Fort Salonga, NY**

DATA INPUT FIELD

A	Site Recharge Parameters	Value	Units	B	Nitrogen Budget Parameters	Value	Units
1	Area of Site	151.65	acres	1	Persons per Dwelling	2.93	persons
2	Precipitation Rate	49.90	inches	2	Nitrogen per Person per Year	10.0	lbs
3	Acreage of Fertilized Landscaping	35.58	acres	3	a. Sanitary Nitrogen Leaching Rate	84%	percent
4	Fraction of Land in above	0.235	fraction	3	b. Treated Sanitary Nitrogen Leaching Rate	100%	percent
5	Evapotranspiration from above	21.20	inches	4	Fertilized Landscaping	35.58	acres
6	Runoff from above	0.50	inches	5	Fertilizer Application Rate (for above)	2.04	lbs/1000 sq ft
7	Acreage of Unfertilized Landscaping	80.91	acres	6	Fertilizer Nitrogen Leaching Rate (for above)	30%	percent
8	Fraction of above	0.534	fraction	7	Fertilized Land (other, if applicable)	0.00	acres
9	Evapotranspiration from above	21.20	inches	8	Fertilizer Application Rate (for above)	0.00	lbs/1000 sq ft
10	Runoff from above	0.50	inches	9	Fertilizer Nitrogen Leaching Rate (for above)	0%	percent
11	Acreage of Unvegetated/Dirt Roads	1.04	acres	10	Outdoor Cat Population	0.19	pets/dwelling
12	Fraction of above	0.007	fraction	11	Cat Waste Nitrogen Load	3.22	lbs/pet/year
13	Evapotranspiration from above	21.20	inches	12	Outdoor Dog Population	0.35	pets/dwelling
14	Runoff from above	0.00	inches	13	Dog Waste Nitrogen Load	4.29	lbs/pet/year
15	Acreage of Water/Ponds	3.70	acres	14	Pet Waste Nitrogen Leaching Rate	25%	percent
16	Fraction of Site in above	0.024	fraction	15	Area of Land Irrigated	35.58	acres
17	Evaporation from above	30.00	inches	16	Irrigation Rate	24.00	inches
18	Makeup Water (if applicable)	0.00	inches	17	Irrigation Nitrogen Leaching Rate	10%	percent
19	Acreage of Natural	15.60	acres	18	Atmospheric Nitrogen Application/Load	0.04	lbs/1000 sq ft
20	Fraction of above	0.103	fraction	19	Atmos. N Leaching Rate (Natural/Wetlands)	25%	percent
21	Evapotranspiration from above	21.20	inches	20	Atmos. N Leaching Rate (Turf/Landscaped)	20%	percent
22	Runoff from above	0.50	inches	21	Atmos. N. Leaching Rate (Ag; Imperv; Other)	40%	percent
23	Acreage of Impervious/Paved/Bldgs	14.82	acres	22	Nitrogen in Water Supply	2.00	mg/l
24	Fraction of Land in above	0.098	fraction	23	Nitrogen in Sanitary Flow	50.00	mg/l
25	Evapotrans. from above	4.99	inches				
26	Runoff from Impervious	0.00	inches				
27	Acreage of Other	0.00	acres				
28	Fraction of Land in above	0.000	fraction				
29	Evapotrans. from above	21.20	inches				
30	Runoff from above	0.00	inches				
31	Acreage of Land Irrigated	35.58	acres				
32	Fraction of Land Irrigated	0.235	fraction				
33	Irrigation Rate	24.00	inches				
34	Number of Dwellings	98	units				
35	Water Use per Dwelling	300	gal/day				
36	Wastewater Design Flow (clubhouse)	600	gal/day				
				C Comments			
				1) Please refer to user manual for data input instructions; updated per LINAP.			
				Total Acreage Check		151.7	100%



Indian Hills - Alternative 5

SITE RECHARGE COMPUTATIONS

A Fertilized Landscaping			B Unfertilized Landscaping				
	Value	Units		Value	Units		
1	A = Fraction of Land in Cover Type	0.235	fraction	1	A = Fraction of Land in Cover Type	0.534	fraction
2	P = Precipitation Rate	49.90	inches	2	P = Precipitation Rate	49.90	inches
3	E = Evapotranspiration Rate	21.20	inches	3	E = Evapotranspiration Rate	21.20	inches
4	Q = Runoff Rate	0.50	inches	4	Q = Runoff Rate	0.50	inches
5	R(a) = P - (E + Q)	28.20	inches	5	R(b) = P - (E + Q)	28.20	inches
6	R(A) = R(a) x A	6.62	inches	6	R(B) = R(b) x A	15.05	inches

C Unvegetated/Dirt Roads			D Water/Ponds				
	Value	Units		Value	Units		
1	A = Fraction of Land in Cover Type	0.007	fraction	1	A = Fraction of Site in Water	0.024	fraction
2	P = Precipitation Rate	49.90	inches	2	P = Precipitation Rate	49.90	inches
3	E = Evapotranspiration Rate	21.20	inches	3	E = Evaporation Rate	30.00	inches
4	Q = Runoff Rate	0.00	inches	4	Q = Runoff Rate	0.00	inches
5	R(c) = P - (E + Q)	28.70	inches	5	M = Makeup Water	0.00	inches
6	R(C) = R(c) x A	0.20	inches	6	R(d) = {P - (E+Q)} - M	19.90	inches
				7	R(D) = R(d) x A	0.49	inches

E Natural			F Impervious/Paved/Roads				
	Value	Units		Value	Units		
1	A = Fraction of Land in Cover Type	0.103	fraction	1	A = Fraction of Land in Cover Type	0.098	fraction
2	P = Precipitation Rate	49.90	inches	2	P = Precipitation Rate	49.90	inches
3	E = Evapotranspiration Rate	21.20	inches	3	E = Evapotranspiration Rate	4.99	inches
4	Q = Runoff Rate	0.50	inches	4	Q = Runoff Rate	0.00	inches
5	R(e) = P - (E + Q)	28.20	inches	5	R(f) = P - (E + Q)	44.91	inches
6	R(E) = R(e) x A	2.90	inches	6	R(F) = R(f) x A	4.39	inches

G Other			H Irrigation Recharge				
	Value	Units		Value	Units		
1	A = Fraction of Land in Cover Type	0.000	fraction	1	A = Fraction of Land Irrigated	0.235	fraction
2	P = Precipitation Rate	49.90	inches	2	I = Irrigation Rate	24.00	inches
3	E = Evapotranspiration Rate	21.20	inches	3	E = Evaptranspiration Rate	21.40	inches
4	Q = Runoff Rate	0.00	inches	4	Q = Runoff Rate	0.00	inches
5	R(g) = P - (E + Q)	28.70	inches	5	R(h) = I - (E + Q)	2.60	inches
6	R(G) = R(g) x A	0.00	inches	6	R(H) = R(h) x A	0.61	inches

I Wastewater Recharge			J Runoff Recharge				
	Value	Units		Value	Units		
1	WDF = Wastewater Design Flow	600	gal/day	1	Q(A) = Runoff from Landscaped	0.117	inches
2	WDF = Wastewater Design Flow	29,280	cu ft/yr	2	Q(B) = Runoff from Unfertilized Landscaping	0.267	inches
3	A = Area of Site	6,605,874	sq ft	3	Q(C) = Runoff from Unvegetated	0.000	inches
4	R(j) = WDF/A	0.00	feet	4	Q(E) = Runoff from Natural	0.051	inches
5	R(I) = Wastewater Recharge	0.05	inches	5	Q(H) = Runoff from Other	0.000	inches
				6	Q(I) = Runoff from Irrigation	0.00	inches
				7	Q(tot) = Q(A)+Q(B)+Q(C)+Q(E)+Q(H)+Q(I)	0.44	inches

Total Site Recharge		
R(T) =	R(A)+R(B)+R(C)+R(D)+R(E)+R(F)+R(G)+R(H)+R(I)+R(J)+Q(tot)	
R(T) =	30.73	inches



SIMULATION OF NITROGEN IN RECHARGE (SONIR)

NELSON, POPE & VOORHIS, LLC MICROCOMPUTER MODEL

Indian Hills - Alternative 5

SITE NITROGEN BUDGET

A	Sanitary Nitrogen-Residential	Value	Units
1	Number of Dwellings	98	units
2	Persons per Dwelling	2.93	capita
3	P = Population	287.14	capita
4	N = Nitrogen per person	10	lbs
6	N = (total; pre loss/removal)	2871.4	lbs
7	LR = Leaching Rate	84%	percent
8	N(S) = P x N x LR	2411.98	lbs
9	N = loss/removed	459.42	lbs

C	Sanitary Nitrogen (Wastewater Design Flow)		
1	CF = Commercial/STP Flow	600	gal/day
2	CF = Commercial/STP Flow	828,915	liters/yr
5	N = Nitrogen	50.00	mg/l
6	N = Nitrogen	91.39	lbs
7	LR = Leaching Rate	84%	percent
8	N(S) = CF x N x LR	34,814,430	milligrams
9	N(S) = Sanitary Nitrogen	76.77	lbs
10	N = loss/removed	14.62	lbs

E	Fertilized Land (Fertilized Landscaping)		
1	A = Area of Land Fertilized	1,549,865	sq ft
2	AR = Application Rate	2.04	lbs/1000 sf
3	N(T) = Nitrogen (total applied)	3161.72	lbs
4	LR = Leaching Rate	30%	percent
5	N(F1) = A x AR x LR	948.52	lbs
6	N = loss/removed	2213.21	lbs

G	Atmospheric Nitrogen (existing condition)		
1	Application Load	0.041	lbs/1000 sf
2	Area of Natural/Wetlands/1000 sf	4,365	1000 sf
3	Leaching Rate	25%	percent
4	Atmos. N Load-1 (natural/wetlands)	44.74	lbs/year
5	Area of turf/landscaped/1000 sf	1,550	1000 sf
6	Leaching Rate	20%	percent
7	Atmos. N Load-2 (golf/turf)	12.71	lbs/year
8	Area of Impervious/Agricult/1000 sf	646	1000 sf
9	Leaching Rate	40%	percent
10	Atmos. N Load-3 (ag; imperv; other)	10.59	lbs/year
11	N(at) = N Load 1 + 2 + 3	68.04	lbs
12	N = loss/removed	200.94	lbs

B	Cat Waste Nitrogen	Value	Units
1	Number of Cats per Dwelling	0.19	cats/dwelling
2	Number of Cats (Cats/dwelling x dwellings)	18	cats
3	Cat Waste Nitrogen Load	3.22	lbs/cat/year
4	N(p) = AR x cats x Adjustment (if applicable)	58.38	lbs/year
5	LR = Leaching Rate	25%	percent
6	N(P) = N(p) x LR	14.59	lbs
7	N = (loss/removed)	43.78	lbs

B'	Dog Waste Nitrogen	Value	Units
1	Number of Dogs per Dwelling	0.35	dogs/dwelling
2	Number of Dogs (Dogs/dwelling x dwellings)	34	dogs
3	Dog Waste Nitrogen Load	4.29	lbs/dog/year
4	N(p) = AR x dogs x Adjustment (if applicable)	147.15	lbs/year
5	LR = Leaching Rate	25%	percent
6	N(P) = N(p) x LR	36.79	lbs
7	N = (loss/removed)	110.36	lbs

D	Water Supply Nitrogen (other than wastewater, if applicable)		
1	WDF = Wastewater Design Flow	0	gal/day
2	WDF = Wastewater Design Flow	0	liters/yr
3	N = Nitrogen in Water Supply	50.00	mg/l
4	N(WW) = WDF x N	0	milligrams
5	N(WW) = Wastewater Nitrogen	0.00	lbs

F	Fertilized Land (Unfertilized Landscaping)		
1	A = Area of Land Fertilized 2	0	sq ft
2	AR = Application Rate	0.00	lbs/1000 sf
3	N(T) = Nitrogen (total applied)	0.00	lbs
4	LR = Leaching Rate	0%	percent
5	N(F2) = A x AR x LR	0.00	lbs
6	N = loss/removed	0.00	lbs

H	Irrigation Nitrogen		
1	R = Irrigation Recharge (inches)	0.61	inches
2	R = Irrigation Rate (feet)	0.0508	feet
3	A = Area of Land Irrigated	1,045,440	sq ft
4	R(I) = R(irr) x A	53,144	cu ft
5	R(I) = Site Irrigation (liters)	1,505,040	liters
6	N = Nitrogen in Water Supply	2.00	mg/l
7	N(T) = Nitrogen (total applied)	6.64	lbs
8	LR = Leaching Rate	10%	percent
9	N(irr) = R(I) x N x LR	301,008	milligrams
10	N(irr) = Irrigation Nitrogen	0.66	lbs
11	N = loss/removed	5.97	lbs

Total Site Nitrogen		
N=	N(S) + N(P) + N(WW) + N(F1) + N(F2) + N(ppt) + N(irr)	
N=	3,557.34	lbs



SIMULATION OF NITROGEN IN RECHARGE (SONIR)

NELSON, POPE & VOORHIS, LLC MICROCOMPUTER MODEL

NAME OF PROJECT

**Indian Hills - Alternative 5
Fort Salonga, NY**

FINAL COMPUTATIONS

A	Nitrogen in Recharge (concentr.)	Value	Units
1	N = Total Nitrogen (lbs)	3,557.34	lbs
2	N = Total Nitrogen (milligrams)	1,615,033,733	milligrams
3	R(T) = Total Recharge (inches)	30.73	inches
4	R(T) = Total Recharge (feet)	2.56	feet
5	A = Area of Site	6,605,874	sq ft
6	R = R(T) x A	16,917,983	cu ft
7	R = Site Recharge Volume	479,117,281	liters
9	NR = N/R	3.37	mg/l

<p>CONCENTRATION OF NITROGEN IN RECHARGE</p> <p style="background-color: #e0e0e0; display: inline-block; padding: 5px;">3.37</p>
--

A	Nitrogen in Recharge	Value	Units
1	N = Total Nitrogen (lbs)	3,557.34	lbs
2	N = Total Nitrogen (milligrams)	1,615,033,733	milligrams
3	R(T) = Total Recharge (inches)	30.73	inches
4	R(T) = Total Recharge (feet)	2.56	feet
5	A = Area of Site	6,605,874	sq ft
6	R = R(T) x A	16,917,983	cu ft
7	R = Site Recharge Volume	479,117,281	liters
9	NR = N/R	3.37	mg/l

Conversions used in SONIR	
Acres x 43,560 = Square Feet	Gallons x 0.1337 = Cubic Feet
Cubic Feet x 7.48052 = Gallons	Gallons x 3.785 = Liters
Cubic Feet x 28.32 = Liters	Grams / 1,000 = Milligrams
Days x 365 = Years	Grams x 0.002205 = Pounds
Feet x 12 = Inches	Milligrams / 1,000 = Grams

B	Site Recharge Summary	Value	Units
1	R(T) = Total Site Recharge	30.73	inches/yr
2	R = Site Recharge Volume	16,917,983	cu ft/yr
3	R = Site Recharge Volume	126,555,311	gal/yr
4	R = Site Recharge Volume	126.56	MG/yr

Nitrogen Load Summary - On-Site	Load	Percent
Sanitary Nitrogen (On-Site Wastewater)	2,488.74	69.96%
Fertilized Landscaping	948.52	26.66%
Dog Waste Nitrogen	36.79	1.03%
Cat Waste Nitrogen	14.59	0.41%
Atmospheric Nitrogen	68.04	1.91%
Irrigation Nitrogen	0.66	0.02%
Total Pounds Nitrogen	3,557.34	100.00%

