

APPENDIX J

WATER RESOURCES-RELATED DOCUMENTS

APPENDIX J-1

SONIR COMPUTER MODEL RESULTS

SIMULATION OF NITROGEN IN RECHARGE (SONIR)

SHEET 1

NELSON, POPE & VOORHIS, LLC MICROCOMPUTER MODEL

NAME OF PROJECT

Indian Hills - Proposed Project - Final EIS
Fort Salonga, NY

7/29/2020

DATA INPUT FIELD

A	Site Recharge Parameters	Value	Units	B	Nitrogen Budget Parameters	Value	Units
1	Area of Site	154.56	acres	1	Persons per Dwelling	1.50	persons
2	Precipitation Rate	49.90	inches	2	Nitrogen per Person per Year	10.0	lbs
3	Acreage of Fertilized Landscaping	31.70	acres	3	a. Sanitary Nitrogen Leaching Rate	84%	percent
4	Fraction of Land in above	0.205	fraction	3	b. Treated Sanitary Nitrogen Leaching Rate	100%	percent
5	Evapotranspiration from above	21.20	inches	4	Fertilized Landscaping	31.70	acres
6	Runoff from above	0.50	inches	5	Fertilizer Application Rate (for above)	1.67	lbs/1000 sq ft
7	Acreage of Unfertilized Landscaping	71.41	acres	6	Fertilizer Nitrogen Leaching Rate (for above)	10%	percent
8	Fraction of above	0.462	fraction	7	Fertilized Land (other, if applicable)	0.00	acres
9	Evapotranspiration from above	21.20	inches	8	Fertilizer Application Rate (for above)	0.00	lbs/1000 sq ft
10	Runoff from above	0.50	inches	9	Fertilizer Nitrogen Leaching Rate (for above)	0%	percent
11	Acreage of Unvegetated/Dirt Roads	4.40	acres	10	Outdoor Cat Population	0.19	pets/dwelling
12	Fraction of above	0.028	fraction	11	Cat Waste Nitrogen Load	3.22	lbs/pet/year
13	Evapotranspiration from above	21.20	inches	12	Outdoor Dog Population	0.35	pets/dwelling
14	Runoff from above	0.00	inches	13	Dog Waste Nitrogen Load	4.29	lbs/pet/year
15	Acreage of Water/Ponds	10.84	acres	14	Pet Waste Nitrogen Leaching Rate	25%	percent
16	Fraction of Site in above	0.070	fraction	15	Area of Land Irrigated	31.70	acres
17	Evaporation from above	30.00	inches	16	Irrigation Rate	27.74	inches
18	Makeup Water (if applicable)	0.00	inches	17	Irrigation Nitrogen Leaching Rate	10%	percent
19	Acreage of Natural	18.81	acres	18	Atmospheric Nitrogen Application/Load	0.04	lbs/1000 sq ft
20	Fraction of above	0.122	fraction	19	Atmos. N Leaching Rate (Natural/Wetlands)	25%	percent
21	Evapotranspiration from above	21.20	inches	20	Atmos. N Leaching Rate (Turf/Landscaped)	20%	percent
22	Runoff from above	0.50	inches	21	Atmos. N. Leaching Rate (Ag; Imperv; Other)	40%	percent
23	Acreage of Impervious/Paved/Bldgs	14.95	acres	22	Nitrogen in Water Supply	2.00	mg/l
24	Fraction of Land in above	0.097	fraction	23	Nitrogen in Sanitary Flow	19.00	mg/l
25	Evapotrans. from above	4.99	inches				
26	Runoff from Impervious	0.00	inches				
27	Acreage of Other	0.00	acres				
28	Fraction of Land in above	0.000	fraction				
29	Evapotrans. from above	21.20	inches				
30	Runoff from above	0.00	inches				
31	Acreage of Land Irrigated	31.70	acres				
32	Fraction of Land Irrigated	0.205	fraction				
33	Irrigation Rate	27.74	inches				
34	Number of Dwellings	86	units				
35	Water Use per Dwelling	300	gal/day				
36	Wastewater Design Flow (clubhouse)	29,750	gal/day				
				C Comments			
				1) Please refer to user manual for data input instructions; updated per LINAP.			

SIMULATION OF NITROGEN IN RECHARGE (SONIR)

SHEET 2

NELSON, POPE & VOORHIS, LLC MICROCOMPUTER MODEL

Indian Hills - Proposed Project - Final EIS

SITE RECHARGE COMPUTATIONS

A	Fertilized Landscaping	Value	Units	B	Unfertilized Landscaping	Value	Units
1	A = Fraction of Land in Cover Type	0.205	fraction	1	A = Fraction of Land in Cover Type	0.462	fraction
2	P = Precipitation Rate	49.90	inches	2	P = Precipitation Rate	49.90	inches
3	E = Evapotranspiration Rate	21.20	inches	3	E = Evapotranspiration Rate	21.20	inches
4	Q = Runoff Rate	0.50	inches	4	Q = Runoff Rate	0.50	inches
5	R(a) = P - (E + Q)	28.20	inches	5	R(b) = P - (E + Q)	28.20	inches
6	R(A) = R(a) x A	5.78	inches	6	R(B) = R(b) x A	13.03	inches

C	Unvegetated/Dirt Roads	Value	Units	D	Water/Ponds	Value	Units
1	A = Fraction of Land in Cover Type	0.028	fraction	1	A = Fraction of Site in Water	0.070	fraction
2	P = Precipitation Rate	49.90	inches	2	P = Precipitation Rate	49.90	inches
3	E = Evapotranspiration Rate	21.20	inches	3	E = Evaporation Rate	30.00	inches
4	Q = Runoff Rate	0.00	inches	4	Q = Runoff Rate	0.00	inches
5	R(c) = P - (E + Q)	28.70	inches	5	M = Makeup Water	0.00	inches
6	R(C) = R(c) x A	0.82	inches	6	R(d) = {P - (E+Q)} - M	19.90	inches
				7	R(D) = R(d) x A	1.40	inches

E	Natural	Value	Units	F	Impervious/Paved/Roads	Value	Units
1	A = Fraction of Land in Cover Type	0.122	fraction	1	A = Fraction of Land in Cover Type	0.097	fraction
2	P = Precipitation Rate	49.90	inches	2	P = Precipitation Rate	49.90	inches
3	E = Evapotranspiration Rate	21.20	inches	3	E = Evapotranspiration Rate	4.99	inches
4	Q = Runoff Rate	0.50	inches	4	Q = Runoff Rate	0.00	inches
5	R(e) = P - (E + Q)	28.20	inches	5	R(f) = P - (E + Q)	44.91	inches
6	R(E) = R(e) x A	3.43	inches	6	R(F) = R(f) x A	4.34	inches

G	Other	Value	Units	H	Irrigation Recharge	Value	Units
1	A = Fraction of Land in Cover Type	0.000	fraction	1	A = Fraction of Land Irrigated	0.205	fraction
2	P = Precipitation Rate	49.90	inches	2	I = Irrigation Rate	27.74	inches
3	E = Evapotranspiration Rate	21.20	inches	3	E = Evapotranspiration Rate	21.40	inches
4	Q = Runoff Rate	0.00	inches	4	Q = Runoff Rate	0.00	inches
5	R(g) = P - (E + Q)	28.70	inches	5	R(h) = I - (E + Q)	6.34	inches
6	R(G) = R(g) x A	0.00	inches	6	R(H) = R(h) x A	1.30	inches

I	Wastewater Recharge	Value	Units	J	Runoff Recharge	Value	Units
1	WDF = Wastewater Design Flow	29,750	gal/day	1	Q(A) = Runoff from Landscaped	0.103	inches
2	WDF = Wastewater Design Flow	1,451,815	cu ft/yr	2	Q(B) = Runoff from Unfertilized Landscaping	0.231	inches
3	A = Area of Site	6,732,634	sq ft	3	Q(C) = Runoff from Unvegetated	0.000	inches
4	R(j) = WDF/A	0.22	feet	4	Q(E) = Runoff from Natural	0.061	inches
5	R(I) = Wastewater Recharge	2.59	inches	5	Q(H) = Runoff from Other	0.000	inches
				6	Q(I) = Runoff from Irrigation	0.00	inches
				7	Q(tot) = Q(A)+Q(B)+Q(C)+Q(E)+Q(H)+Q(I)	0.39	inches

Total Site Recharge			
R(T) =	R(A)+R(B)+R(C)+R(D)+R(E)+R(F)+R(G)+R(H)+R(I)+R(J)+Q(tot)		
R(T) =	33.08	inches	

SIMULATION OF NITROGEN IN RECHARGE (SONIR)

SHEET 3

NELSON, POPE & VOORHIS, LLC MICROCOMPUTER MODEL

Indian Hills - Proposed Project - Final EIS

SITE NITROGEN BUDGET

A Sanitary Nitrogen-Residential				B Cat Waste Nitrogen			
		<i>Value</i>	<i>Units</i>			<i>Value</i>	<i>Units</i>
1	Number of Dwellings	0	units	1	Number of Cats per Dwelling	0.19	cats/dwelling
2	Persons per Dwelling	1.50	capita	2	Number of Cats (Cats/dwelling x dwellings)	16	cats
3	P = Population	0.00	capita	3	Cat Waste Nitrogen Load	3.22	lbs/cat/year
4	N = Nitrogen per person	10	lbs	4	N(p) = AR x cats x Adjustment (if applicable)	51.23	lbs/year
6	N = (total; pre loss/removal)	0	lbs	5	LR = Leaching Rate	25%	percent
7	LR = Leaching Rate	84%	percent	6	N(P) = N(p) x LR	12.81	lbs
8	N(S) = P x N x LR	0.00	lbs	7	N = (loss/removed)	38.42	lbs
9	N = loss/removed	0.00	lbs				
C Sanitary Nitrogen (Wastewater Design Flow)				B' Dog Waste Nitrogen			
						<i>Value</i>	<i>Units</i>
1	CF = Commercial/STP Flow	29,750	gal/day	1	Number of Dogs per Dwelling	0.35	dogs/dwelling
2	CF = Commercial/STP Flow	41,100,369	liters/yr	2	Number of Dogs (Dogs/dwelling x dwellings)	30	dogs
5	N = Nitrogen	19.00	mg/l	3	Dog Waste Nitrogen Load	4.29	lbs/dog/year
6	N = Nitrogen	1721.90	lbs	4	N(p) = AR x dogs x Adjustment (if applicable)	129.13	lbs/year
7	LR = Leaching Rate	100%	percent	5	LR = Leaching Rate	25%	percent
8	N(S) = CF x N x LR	780,907,006	milligrams	6	N(P) = N(p) x LR	32.28	lbs
9	N(S) = Sanitary Nitrogen	1721.90	lbs	7	N = (loss/removed)	96.85	lbs
10	N = loss/removed	0.00	lbs				
E Fertilized Land (Fertilized Landscaping)				D Water Supply Nitrogen (other than wastewater, if applicable)			
1	A = Area of Land Fertilized	1,380,852	sq ft	1	WDF = Wastewater Design Flow	0	gal/day
2	AR = Application Rate	1.67	lbs/1000 sf	2	WDF = Wastewater Design Flow	0	liters/yr
3	N(T) = Nitrogen (total applied)	2304.86	lbs	3	N = Nitrogen in Water Supply	19.00	mg/l
4	LR = Leaching Rate	10%	percent	4	N(WW) = WDF x N	0	milligrams
5	N(F1) = A x AR x LR	230.49	lbs	5	N(WW) = Wastewater Nitrogen	0.00	lbs
6	N = loss/removed	2074.38	lbs				
G Atmospheric Nitrogen (existing condition)				F Fertilized Land (Unfertilized Landscaping)			
1	Application Load	0.041	lbs/1000 sf	1	A = Area of Land Fertilized 2	0	sq ft
2	Area of Natural/Wetlands/1000 sf	4,402	1000 sf	2	AR = Application Rate	0.00	lbs/1000 sf
3	Leaching Rate	25%	percent	3	N(T) = Nitrogen (total applied)	0.00	lbs
4	Atmos. N Load-1 (natural/wetlands)	45.12	lbs/year	4	LR = Leaching Rate	0%	percent
5	Area of turf/landscaped/1000 sf	1,381	1000 sf	5	N(F2) = A x AR x LR	0.00	lbs
6	Leaching Rate	20%	percent	6	N = loss/removed	0.00	lbs
7	Atmos. N Load-2 (golf/turf)	11.32	lbs/year				
8	Area of Impervious/Agriculture/1000 sf	651	1000 sf				
9	Leaching Rate	40%	percent				
10	Atmos. N Load-3 (ag; imperv; other)	10.68	lbs/year				
11	N(at) = N Load 1 + 2 + 3	67.13	lbs				
12	N = loss/removed	196.68	lbs				
H Irrigation Nitrogen							
1	R = Irrigation Recharge (inches)	1.30	inches				
2	R = Irrigation Rate (feet)	0.1084	feet				
3	A = Area of Land Irrigated	1,208,354	sq ft				
4	R(I) = R(irr) x A	130,938	cu ft				
5	R(I) = Site Irrigation (liters)	3,708,154	liters				
6	N = Nitrogen in Water Supply	2.00	mg/l				
7	N(T) = Nitrogen (total applied)	16.35	lbs				
8	LR = Leaching Rate	10%	percent				
9	N(irr) = R(I) x N x LR	741,631	milligrams				
10	N(irr) = Irrigation Nitrogen	1.64	lbs				
11	N = loss/removed	14.72	lbs				

Total Site Nitrogen			
N=	N(S) + N(P) + N(WW) + N(F1) + N(F2) + N(ppt) + N(irr)		
N=	2,066.24	lbs	

SIMULATION OF NITROGEN IN RECHARGE (SONIR)

SHEET 4

NELSON, POPE & VOORHIS, LLC MICROCOMPUTER MODEL

NAME OF PROJECT

Indian Hills - Proposed Project - Final EIS
Fort Salonga, NY

FINAL COMPUTATIONS

A	Nitrogen in Recharge (concentr.)	Value	Units
1	N = Total Nitrogen (lbs)	2,066.24	lbs
2	N = Total Nitrogen (milligrams)	938,071,463	milligrams
3	R(T) = Total Recharge (inches)	33.08	inches
4	R(T) = Total Recharge (feet)	2.76	feet
5	A = Area of Site	6,732,634	sq ft
6	R = R(T) x A	18,561,756	cu ft
7	R = Site Recharge Volume	525,668,940	liters
9	NR = N/R	1.78	mg/l

CONCENTRATION OF
NITROGEN IN RECHARGE

1.78

A	Nitrogen in Recharge	Value	Units
1	N = Total Nitrogen (lbs)	2,066.24	lbs
2	N = Total Nitrogen (milligrams)	938,071,463	milligrams
3	R(T) = Total Recharge (inches)	33.08	inches
4	R(T) = Total Recharge (feet)	2.76	feet
5	A = Area of Site	6,732,634	sq ft
6	R = R(T) x A	18,561,756	cu ft
7	R = Site Recharge Volume	525,668,940	liters
9	NR = N/R	1.78	mg/l

Conversions used in SONIR

Acres x 43,560 = Square Feet	Gallons x 0.1337 = Cubic Feet
Cubic Feet x 7.48052 = Gallons	Gallons x 3.785 = Liters
Cubic Feet x 28.32 = Liters	Grams / 1,000 = Milligrams
Days x 365 = Years	Grams x 0.002205 = Pounds
Feet x 12 = Inches	Milligrams / 1,000 = Grams

B	Site Recharge Summary	Value	Units
1	R(T) = Total Site Recharge	33.08	inches/yr
2	R = Site Recharge Volume	18,561,756	cu ft/yr
3	R = Site Recharge Volume	138,851,590	gal/yr
4	R = Site Recharge Volume	138.85	MG/yr

Nitrogen Load Summary - On-Site

	Load	Percent
Sanitary Nitrogen (On-Site Wastewater)	1,721.90	83.34%
Fertilized Landscaping	230.49	11.15%
Dog Waste Nitrogen	32.28	1.56%
Cat Waste Nitrogen	12.81	0.62%
Atmospheric Nitrogen	67.13	3.25%
Irrigation Nitrogen	1.64	0.08%
Total Pounds Nitrogen	2,066.24	100.00%